



Certificat

Certificate

Certificate of constancy of performance for products

In compliance with the Regulation 305/2011/UE of the European Parliament and of the Council of 9 March 2011.
(Construction Products Regulation or CPR)

Delivered by :

Notified Body :

AFNOR Certification

Identification number :

0333

Address :

**11 rue Francis de Pressensé
FR - 93571 LA PLAINE SAINT-DENIS CEDEX**

Delivered to :

Company:

COOPER Fulleon Ltd.

Address :

**Llantarnam Park, Cwmbran
GWENT NP44 3AW - United Kingdom**

Manufacturing site(s) :

Gwent - United Kingdom

Product : Visual alarm device - SYMPHONI LX WALL BASE

Detailed description of product : Appendix

AFNOR Certification attests that the provisions concerning the assessment and verification of constancy of performance and the performances described in annex ZA of the standard(s), below stated, under system 1 are applied and that the product fulfills the provisions described in annex ZA of the standard(s) below designated.

Fire detection and fire alarm systems

EN 54-23:2010 - Fire alarm devices - Visual alarm devices

Certificate number :

0333-CPR-075445

Conditions and certificate validity period : 9 August 2018

This certificate was first issued on 9 August 2013. Unless suspension or canceled, this certificate remains valid as long as the conditions laid down in the reference technical specifications or the manufacturing conditions in the factory or the factory production control or the product itself are not modified significantly.

It cancels and replaces the certificate issued on 9 August 2013.

Date of certificate delivery : 2 September 2013

Managing Director

Florence MÉAUX



005 - 2013/05 -



Certificat

Certificate

Appendix to the certificate

Company : COOPER Fulleon Ltd.
Certificate number : 0333-CPR-075445
Manufacturing site(s) : Gwent - United Kingdom
Date of certificate delivery : 2 September 2013

Product's description :

Identification of certified product(s) (Reference)	Product designation / Use	File number
SYMPHONI LX WALL BASE	Visual alarm device Type A (indoor) Category : W (wall mounted) Light colour : White or Red	075.1470