Select your language

- German
- English
- Spanish
- French
- Dutch
- Italian
- Polish
- Czech
- Russian
- Norw egian Bokmål

Worldwide English



NZN2-4-XKS - Screw connection, 4p, standard, size 2



266750 NZM2-4-XKS

Overview Specifications Resources



266750 NZM2-4-XKS

Screw connection, 4p, standard, size 2

∃L-Nummer (Norway)

1358896

Optional accessories for the circuit-breaker series NZM offers a comprehensive portfolio of application options for use world wide. The mounting is always flexible and easy thanks to the modular function groups. Notes: part no. contains parts for a terminal located at top or bottomfor 3 or 4 pole switches. Standard connection with all NZM2, FN2 and N2 circuit-breakers. Conversion kit for circuit-breaker with box terminal. Use special cable lug narrow version. fitted within the switch housing. If a busbar is used, insulation (400 mm) e.g sleeving and a NZM2(4)-XKSA cover are required. Ue □ 525 VAC. For all other connection material e.g. cables, flat conductors, a NZM2(-4)-XKSA shroud must be used. Can be used for: NZM2(-4), RN2(-4), N(NO)2(-4)

Delivery program

- Design verification as per IEC/EN 61439
- Technical data ETIM 7.0
- Dimensions

Delivery program

Number of conductors

4 pole

Accessories

Screw connection

Rated current [l_n]
Ou 300, Al 250 A

For use with

NZM2-4, PN2-4, N(S)2-4

Terminal capacities

Type of conductorQu/Al cable

Copper cable lugs

Aluminium cable lug

Terminal capacities flexible

1 x 10 - 185

2 x 4 - 70

1 x 10 - 50

2 x 10 - 50 mm²

AWG/kcmil

1 x 11 - 3/0

2 x 12

1 x 8 - 1/0

2 x 8 - 1/0 mm²

Terminal capacities

Ou strip (number of segments x width x segment thickness)

 \Box 2 x 16 x 0.8 mm²

Copper busbar width x thickness [Width]

 \Box 16 x 5 mm

Notes

Type contains parts for 3 or 4-pole switches on top or bottom of switch.

Standard connection with all NZV2, PN2 and N2 circuit-breakers.

Conversion kit for circuit-breaker with box terminal.

Use only specialized cable lugs with a narrow design; see NZM*XKS* types. Otherwise, NZM*XKP phase disconnectors must be used, even for insulated cable lugs.

Fitted within the switch housing.

If a busbar is used, insulation (400 mm) e.g sleeving and a NZM2(-4)-XKSA cover are required.

U_e □ 525 V AC:

 Bei allen anderen Anschlussmaterialien, z.B. Kabel, Bänder, ist eine Abdeckung NZW2(-4)-XKSA zu verwenden.

Design verification as per IEC/EN 61439

IEC/EN 61439 design verification

10.2 Strength of materials and parts 10.2.2 Corrosion resistance

Meets the product standard's requirements.

10.2 Strength of materials and parts 10.2.3.1 Verification of thermal stability of enclosures

Meets the product standard's requirements.

10.2 Strength of materials and parts 10.2.3.2 Verification of resistance of insulating materials to normal heat Meets the product standard's requirements.

10.2 Strength of materials and parts 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects

Meets the product standard's requirements.

10.2 Strength of materials and parts10.2.4 Resistance to ultra-violet (UV) radiation

Meets the product standard's requirements.

10.2 Strength of materials and parts 10.2.5 Lifting

Does not apply, since the entire switchgear needs to be evaluated.

10.2 Strength of materials and parts 10.2.6 Mechanical impact

Does not apply, since the entire switchgear needs to be evaluated.

10.2 Strength of materials and parts 10.2.7 Inscriptions

Meets the product standard's requirements.

10.3 Degree of protection of ASSEVBLIES

Does not apply, since the entire switchgear needs to be evaluated.

10.4 Clearances and creepage distances

Meets the product standard's requirements.

10.5 Protection against electric shock

Does not apply, since the entire switchgear needs to be evaluated.

10.6 Incorporation of switching devices and components

Does not apply, since the entire switchgear needs to be evaluated.

10.7 Internal electrical circuits and connections

Is the panel builder's responsibility.

10.8 Connections for external conductors

Is the panel builder's responsibility.

10.9 Insulation properties 10.9.2 Power-frequency electric strength

Is the panel builder's responsibility.

10.9 Insulation properties 10.9.3 Impulse withstand voltage

Is the panel builder's responsibility.

10.9 Insulation properties 10.9.4 Testing of enclosures made of insulating material

Is the panel builder's responsibility.

10.10 Temperature rise

The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.

10.11 Short-circuit rating

Is the panel builder's responsibility. The specifications for the switchgear must be observed.

10.12 Electromagnetic compatibility

Is the panel builder's responsibility. The specifications for the switchgear must be observed.

10.13 Mechanical function

The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Technical data ETIM 7.0

Low-voltage industrial components (EG000017) / Wiring set for power circuit breaker (EC002050)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Orcuit breaker (LV < 1 kV) / Wiring set for circuit breaker (ecl@ss10.0.1-27-37-04-24 [ACN957011])

Suitable for number of poles

Model Other

Dimensions



CAD data

- Product-specific CAD data (Web)
- 3D Preview (Web)

DWG files

DA-CD-nzm2_xks File (Web)

Step files

DA-CS-nzm2_xks File (Web)

Dimensions single product



Line drawing Shroud for screw terminals

- □ 3 pole
- □ 4 pole

3D drawing



Line drawing Screw connection

Product photo



Instruction Leaflet

IL01206005Z
 Asset
 (PDF, Language independent)

Download-Center

- Download-Center (this item) Eaton EVEA Download-Center - download data for this item
- Download-Center Eaton EVEA Download-Center

Generate data sheet in PDF format

Generate data sheet in Excel format

Write a comment Imprint Privacy Policy Legal Disclaimer Terms and Conditions
© 2022 by Eaton Industries GmbH