

# Specifications



## Eaton 101454

Eaton Moeller® series BBA Busbar adapter,  
90 mm, 32 A, DIN rail: 3

### General specifications

<b>PRODUCT NAME</b>	Eaton Moeller® series BBA Accessory Busbar adapter
<b>CATALOG NUMBER</b>	101454
<b>MODEL CODE</b>	BBA0R-32
<b>EAN</b>	4015081013746
<b>PRODUCT LENGTH/DEPTH</b>	200 mm
<b>PRODUCT HEIGHT</b>	73 mm
<b>PRODUCT WIDTH</b>	90 mm
<b>PRODUCT WEIGHT</b>	0.494 kg

<b>CERTIFICATIONS</b>	Certified by UL for use in Canada IEC60439-1 UL 508A CSA-C22.2 No. 14 UL File No.: E300273 UL UL Category Control No.: NMTR; NMTR7 CE
-----------------------	--

<b>GLOBAL CATALOG</b>	101454
-----------------------	--------



Powering Business Worldwide

## Product specifications

<b>SPECIAL FEATURES</b>	Terminal capacity: 6 mm <sup>2</sup> (AWG 10)
<b>TYPE</b>	<ul style="list-style-type: none"> <li>• Busbar adapter</li> <li>• SASY Busbar system 60 mm</li> </ul>
<b>VOLTAGE RATING (UL CSA 13)</b>	600 V AC, UL/CSA
<b>ADAPTER WIDTH</b>	90 mm
<b>AMBIENT OPERATING TEMPERATURE - MAX</b>	55 °C
<b>AMBIENT OPERATING TEMPERATURE - MIN</b>	-25 °C
<b>BUSBAR DISTANCE</b>	60 mm
<b>BUSBAR THICKNESS - MAX</b>	10 mm
<b>BUSBAR THICKNESS - MIN</b>	5 mm
<b>NOMINAL CURRENT</b>	32 A
<b>NUMBER OF DIN RAILS</b>	3
<b>RAIL WIDTH</b>	35 mm
<b>VOLTAGE RATING AT AC</b>	690 V
<b>ELECTRIC CONNECTION TYPE</b>	3 conductors AWG 10
<b>HEAT DISSIPATION PER POLE, CURRENT-DEPENDENT PVID</b>	0 W
<b>STATIC HEAT DISSIPATION, NON-CURRENT-DEPENDENT PVS</b>	0 W
<b>EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT PVID</b>	2.4 W
<b>10.2.2 CORROSION RESISTANCE</b>	Meets the product standard's requirements.
<b>10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES</b>	Meets the product standard's requirements.
<b>10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT</b>	Meets the product standard's requirements.
<b>10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS</b>	Meets the product standard's requirements.
<b>10.2.4 RESISTANCE TO</b>	Meets the product

## Resources

<b>BROCHURES</b>	<a href="#">eaton-xeffect-sasy60i-customer-success-story-css-wagner-mueller-en-us.pdf</a>
<b>CATALOGS</b>	<a href="#">Product Range Catalog Switching and protecting motors</a>
<b>CERTIFICATION REPORTS</b>	<a href="#">eaton-xeffect-sasy-60i-declaration-of-conformity.pdf</a>
<b>DECLARATIONS OF CONFORMITY</b>	<a href="#">eaton-accessory-declaration-of-conformity-eu250602en.pdf</a> <a href="#">eaton-accessory-declaration-of-conformity-uk251085en.pdf</a>
<b>DRAWINGS</b>	<a href="#">eaton-manual-motor-starters-bba-busbar-adapter-dimensions-011.eps</a> <a href="#">eaton-manual-motor-starters-bba-busbar-adapter-3d-drawing-003.eps</a>
<b>ECAD MODEL</b>	<a href="#">ETN.101454.edz</a>
<b>INSTALLATION INSTRUCTIONS</b>	<a href="#">IL03402015Z</a>
<b>MCAD MODEL</b>	<a href="#">DA-CS-bba0r_32</a> <a href="#">DA-CD-bba0r_32</a>
<b>TECHNICAL DATA SHEETS</b>	<a href="#">eaton-xeffect-sasy-60i-fk4300-1167gb-en-us.pdf</a>

<b>ULTRA-VIOLET (UV) RADIATION</b>	standard's requirements.
<b>10.2.5 LIFTING</b>	Does not apply, since the entire switchgear needs to be evaluated.
<b>10.2.6 MECHANICAL IMPACT</b>	Does not apply, since the entire switchgear needs to be evaluated.
<b>10.2.7 INSCRIPTIONS</b>	Meets the product standard's requirements.
<b>10.3 DEGREE OF PROTECTION OF ASSEMBLIES</b>	Does not apply, since the entire switchgear needs to be evaluated.
<b>10.4 CLEARANCES AND CREEPAGE DISTANCES</b>	Meets the product standard's requirements.
<b>10.5 PROTECTION AGAINST ELECTRIC SHOCK</b>	Does not apply, since the entire switchgear needs to be evaluated.
<b>10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS</b>	Does not apply, since the entire switchgear needs to be evaluated.
<b>10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS</b>	Is the panel builder's responsibility.
<b>10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS</b>	Is the panel builder's responsibility.
<b>10.9.2 POWER-FREQUENCY ELECTRIC STRENGTH</b>	Is the panel builder's responsibility.
<b>10.9.3 IMPULSE WITHSTAND VOLTAGE</b>	Is the panel builder's responsibility.
<b>10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL</b>	Is the panel builder's responsibility.
<b>10.10 TEMPERATURE RISE</b>	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
<b>10.11 SHORT-CIRCUIT RATING</b>	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
<b>10.12 ELECTROMAGNETIC COMPATIBILITY</b>	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
<b>10.13 MECHANICAL FUNCTION</b>	The device meets the requirements, provided the information in the

	instruction leaflet (IL) is observed.
<b>MOUNTING RAIL ARMAMENT</b>	2 mounting rails
<b>RATED OPERATION CURRENT (IE)</b>	32 A

---

**PROJECT NAME:**

---

**PROJECT NUMBER:**

---

**PREPARED BY:**

---

**DATE:**

---



**Eaton Corporation plc**  
Eaton House  
30 Pembroke Road  
Dublin 4, Ireland  
Eaton.com

Follow us on social media to get the latest product and support information.

