



Instructions Designed as tool-less plug connection Use as auxiliary contact DLA-XHT...

### **DESIGN VERIFICATION AS PER IEC/EN 61439**

#### Technical data for design verification

Rated operational current for specified heat dissipation  $[I_n]$  22 A

Heat dissipation per pole, current-dependent  $[\mathsf{P}_{\text{id}}]$  0 W

Equipment heat dissipation, current-dependent [P<sub>id</sub>] 0 W

Static heat dissipation, non-current-dependent  $[\mathrm{P}_{\mathrm{vs}}]$  0 W

Heat dissipation capacity [P<sub>diss</sub>] 0 W

Operating ambient temperature min. -25  $^\circ\mathrm{C}$ 

Operating ambient temperature max. +60 °C

### IEC/EN 61439 design verification

10.2 Strength of materials and parts10.2.2 Corrosion resistanceMeets the product standard's requirements.

10.2 Strength of materials and parts10.2.3.1 Verification of thermal stability of enclosuresMeets the product standard's requirements.

10.2 Strength of materials and parts10.2.3.2 Verification of resistance of insulating materials to normal heatMeets the product standard's requirements.

10.2 Strength of materials and parts 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects Meets the product standard's requirements.

10.2 Strength of materials and parts10.2.4 Resistance to ultra-violet (UV) radiationMeets the product standard's requirements.

10.2 Strength of materials and parts10.2.5 LiftingDoes not apply, since the entire switchgear needs to be evaluated.

10.2 Strength of materials and parts10.2.6 Mechanical impactDoes not apply, since the entire switchgear needs to be evaluated.

10.2 Strength of materials and parts10.2.7 InscriptionsMeets the product standard's requirements.

10.3 Degree of protection of ASSEVBLIES Does not apply, since the entire switchgear needs to be evaluated.

10.4 Clearances and creepage distances Meets the product standard's requirements.

10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated.

10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated.

10.7 Internal electrical circuits and connections Is the panel builder's responsibility.

10.8 Connections for external conductors Is the panel builder's responsibility.

10.9 Insulation properties10.9.2 Pow er-frequency electric strength Is the panel builder's responsibility. 10.9 Insulation properties10.9.3 Impulse withstand voltageIs the panel builder's responsibility.

10.9 Insulation properties10.9.4 Testing of enclosures made of insulating materialIs the panel builder's responsibility.

10.10 Temperature rise The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.

10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed.

10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed.

10.13 Mechanical function The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

# **TECHNICAL DATA ETIM 7.0**

Low-voltage industrial components (EG000017) / Accessories for low-voltage switch technology (EC002498)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Component for low-voltage switching technology / Component for low-voltage switch technology (accessories) (ecl@ss10.0.1-27-37-13-92 [AKN570013])

Type of accessory Connecting bridge

# **APPROVALS**

Product Standards IEC/EN 60947-4-1; UL 508; CSA-C22.2 No. 14-05; **CE** marking

UL File No. E36332

UL Category Control No. NLRV

CSA File No. 012528

CSA Class No. 3211-05

North America Certification UL listed, CSA certified

Specially designed for North America No



Imprint | Privacy Policy | Legal Disclaimer | Terms and Conditions © 2021 by Eaton Industries GmbH