







266015 N2-4-200

Overview

Specifications

Resources







## **DELIVERY PROGRAM**

Delivery program

Technical data

Product range Switch-disconnectors

Design verification as per IEC/EN 61439

Protective function Disconnectors/main switches

Standard/Approval

Technical data ETIM 7.0

Installation type Fixed

Dimensions

Construction size

N2

Description

Main switch characteristics including positive drive to IEC/EN 60204 and VDE 0113.

Isolating characteristics to IEC/EN 60947-3 and VDE 0660.

Busbar tag shroud to VDE 0160 Part 100.

Number of poles 4 pole Standard equipment Screw connection Switch positions I, +, 0 Rated current = rated uninterrupted current  $[I_n = I_u]$ Short-circuit protection max. fuse gLcharacteristic 250 A gL **TECHNICAL DATA General** Standards IEC/EN 60947 Protection against direct contact Finger and back-of-hand proof to DIN EN 50274/VDE 0106 part 110 Climatic proofing Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30 Ambient temperature Ambient temperature, storage - 40 - + 70 °C Ambient temperature Operation -25 - +70 °C

-25 - +70 °C

Mechanical shock resistance (10 ms half-sinusoidal shock) according to IEC 60068-2-27 20 (half-sinusoidal shock 20 ms) g

Safe isolation to EN 61140

Between auxiliary contacts and main contacts 500 V AC

Safe isolation to BN 61140 between the auxiliary contacts 300 V AC

Mounting position Mounting position

Vertical and 90° in all directions



With residual-current release XFI.

- NZM1, N1, NZM2, N2: vertical and 90° in all directions

with plug-in adapter elements

- NZM1, N1, NZM2, N2: vertical, 90° right/left

with withdrawable unit:

- NZMB, N3: vertical, 90 ° left

- NZM4, N4: vertical

with remote operator:

- NZM2, N(S)2, NZM3, N(S)3, NZM4, N(S)4: vertical and 90° in all directions

Direction of incoming supply as required

Degree of protection
Device
In the area of the HM devices: IP20 (basic protection type)

Degree of protection Enclosures With insulating surround: IP40 With door coupling rotary handle: IP66

Degree of protection
Terminations
Tunnel terminal: IP10
Phase isolator and band terminal: IP00

#### **Switch-disconnectors**

Rated surge voltage invariability  $[U_{mp}]$  Wain contacts

Rated surge voltage invariability [U<sub>mp</sub>] Auxiliary contacts 6000 V

Rated operational voltage [Ue] 690 V AC

Rated operating frequency [f] 50/60 Hz

Rated current = rated uninterrupted current [ $I_n = I_u$ ] 200 A

Overvoltage category/pollution degree III/3

Rated insulation voltage [U<sub>i</sub>] 690 V

Use in unearthed supply systems □ 690 V

Other technical data (sheet catalogue)
Weight
Temperature dependency, Derating
Effective power loss

## Rated short-circuit making capacity [Icm ]

690 V 50/60 H [lc] 5.5 kA

#### Rated short-time withstand current

 $t = 0.3 s [l_{cw}]$ 3.5 kA

 $t = 1 s [l_{cw}]$ 3.5 kA

The rated short-time withstand current for PN2/N2 in conjunction with earth-fault release NZM2-4-

### Rated conditional short-circuit current [kA]

With back-up fuse PN2(N2)-160...250: 250 A gG/gL

400 ... 415 V 100 kA

690 V 80 kA

With downstreamfuse PN2(N2)-160...250: 250 A gG/gL

400 ... 415 V 100 kA

690 V 80 kA

#### Rated making and breaking capacity

Rated operational current [l<sub>e</sub>] AC-22/23A 415 V [l<sub>e</sub>] 200 A

Rated operational current [I $_{\rm e}$ ] AC-22/23A 690 V [I $_{\rm e}$ ] 200 A

Lifespan, mechanical [Operations] 20000

Max. operating frequency 120 Ops/h

### Lifespan, electrical

AC-1 400 V 50/60 Hz [Operations] AC-1 415 V 50/60 Hz [Operations] 7500

AC-1 690 V 50/60 Hz [Operations] 5000

AC-3 400 V 50/60 Hz [Operations] 6000

AC-3 415 V 50/60 Hz [Operations] 6000

AC-3 690 V 50/60 Hz [Operations] 4000

## **Terminal capacity**

Standard equipment Screw connection

Optional accessories Box terminal Tunnel terminal connection on rear

Copper conductors and cables Box terminal Solid 1 x (10 - 16) 2 x (6 - 16) mm<sup>2</sup>

Copper conductors and cables Box terminal Stranded 1 x (25 - 185) 2 x (25 - 70) mm<sup>2</sup>

Copper conductors and cables Tunnel terminal Solid 1 x 16 mm<sup>2</sup> Copper conductors and cables Tunnel terminal Stranded 1-hole 1 x (25 - 185) mm²

Copper conductors and cables
Bolt terminal and rear-side connection
Direct on the switch
Solid
1 x (10 - 16)
2 x (6 - 16) mm²

Copper conductors and cables
Bolt terminal and rear-side connection
Direct on the switch
Stranded
1 x (25 - 185)
2 x (25 - 70) mm<sup>2</sup>

Al conductors, Al cable Tunnel terminal Solid 1 x 16 mm<sup>2</sup>

Al conductors, Al cable Tunnel terminal Stranded 1-hole 1 x (25 - 185) mm²

Al conductors, Al cable
Bolt terminal and rear-side connection
Direct on the switch
Solid
1 x (10 - 16)
2 x (10 - 16) mm²

Al conductors, Al cable
Bolt terminal and rear-side connection
Direct on the switch
Stranded
1 x (25 - 185)
2 x (25 - 70) mm<sup>2</sup>

Qu strip (number of segments x width x segment thickness)
Box terminal [min.]
2 x 9 x 0.8 mm

Ou strip (number of segments x width x segment

thickness)
Box terminal [max.]
10 x 16 x 0.8
(2x) 8 x 15.5 x 0,8 mm

Ou strip (number of segments x width x segment thickness)

Bolt terminal and rear-side connection

Flat copper strip, with holes [min.]

2 x 16 x 0.8 mm

Ou strip (number of segments x width x segment thickness)

Bolt terminal and rear-side connection

Flat copper strip, with holes [max.]

10 x 24 x 0.8 mm

Copper busbar (width x thickness) [mm] Bolt terminal and rear-side connection Screw connection M8

Copper busbar (width x thickness) [mm] Bolt terminal and rear-side connection Direct on the switch [min.] 16 x 5 mm

Copper busbar (width x thickness) [mm] Bolt terminal and rear-side connection Direct on the switch [max.] 24 x 8 mm

## **DESIGN VERIFICATION AS PER IEC/EN 61439**

#### Technical data for design verification

Rated operational current for specified heat dissipation [I $_{\text{N}}$ ] 200 A

Equipment heat dissipation, current-dependent  $\left[P_{id}\right]$  30.72 W

Operating ambient temperature min. -25  $^{\circ}$ C

Operating ambient temperature max. +70 °C

#### IEC/EN 61439 design verification

10.2 Strength of materials and parts10.2.2 Corrosion resistanceMeets the product standard's requirements.

10.2 Strength of materials and parts10.2.3.1 Verification of thermal stability of enclosuresMeets the product standard's requirements.

10.2 Strength of materials and parts10.2.3.2 Verification of resistance of insulating materials to normal heatMeets the product standard's requirements.

10.2 Strength of materials and parts 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects Weets the product standard's requirements.

10.2 Strength of materials and parts 10.2.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements.

10.2 Strength of materials and parts10.2.5 LiftingDoes not apply, since the entire switchgear needs to be evaluated.

10.2 Strength of materials and parts
10.2.6 Mechanical impact
Does not apply, since the entire switchgear needs
to be evaluated.

10.2 Strength of materials and parts10.2.7 InscriptionsMeets the product standard's requirements.

10.3 Degree of protection of ASSEVBLIES Does not apply, since the entire switchgear needs to be evaluated.

Meets the product standard's requirements.

10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated.

10.6 Incorporation of switching devices and components

Does not apply, since the entire switchgear needs to be evaluated.

10.7 Internal electrical circuits and connections Is the panel builder's responsibility.

10.8 Connections for external conductors Is the panel builder's responsibility.

10.9 Insulation properties 10.9.2 Power-frequency electric strength Is the panel builder's responsibility.

10.9 Insulation properties 10.9.3 Impulse withstand voltage Is the panel builder's responsibility.

10.9 Insulation properties10.9.4 Testing of enclosures made of insulating materialIs the panel builder's responsibility.

10.10 Temperature rise
The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.

10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed.

10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed.


10.13 Mechanical function

The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

## **TECHNICAL DATA ETIM 7.0**

Low-voltage industrial components (EG000017) / Switch disconnector (EC000216) Bectric engineering, automation, process control engineering / Low-voltage switch technology / Off-load switch, circuit breaker, control switch / Switch disconnector (ecl@ss10.0.1-27-37-14-03 [AKF060013]) Version as main switch Yes Version as maintenance-/service switch Yes Version as safety switch Version as emergency stop installation Version as reversing switch Number of switches Max. rated operation voltage Ue AC 690 V Rated operating voltage 690 - 690 V Rated permanent current lu 200 A Rated permanent current at AC-23, 400 V 0 A Rated permanent current at AC-21, 400 V

0 A



Suitable for front mounting 4-hole No
Suitable for front mounting centre No
Suitable for distribution board installation Yes
Suitable for intermediate mounting Yes
Colour control element Black
Type of control element Rocker lever
Interlockable Yes
Type of electrical connection of main circuit Screw connection
Degree of protection (IP), front side IP20
Degree of protection (NEVA)

# **DIMENSIONS**



Blow	out area,	mnimum clearance t	to adjacent
parts			

☐ Minimum clearance to adjacent parts









Imprint | Privacy Policy | Legal Disclaimer | Terms and Conditions © 2022 by Eaton Industries GmbH