



NZM N2-4-VX100

Overview

Specifications

Resources







## **DELIVERY PROGRAM**

Delivery program

Product range Circuit-breaker

Technical data

Design verification as per IEC/EN 61439

Protective function

Systems, cable, selectivity and generator protection

Technical data ETIM 7.0

Standard/Approval IEC

Characteristics

Installation type Fixed

Dimensions

Release system Bectronic release

Construction size NZM2

Description

LSI overload protection and delayed and non-delayed short-circuit protective device

 $Rms.\ value$  measurement and "thermal memory" USB interface for configuration and test function with

Power Xpert Protection Manager software Optionally communication-capable with interface module and

internal Modbus RTU module or CAM

Number of poles 4 pole

Standard equipment Screw connection

#### **Switching capacity**

 $400/415 \text{ V } 50 \text{ Hz } [l_{cu}]$  50 kA

# Rated current = rated uninterrupted current $[I_n = I_u]$

Rated current = rated uninterrupted current [ $I_n = I_u$ ] 100 A

Neutral conductor [% of phase conductor] 100 CSA

## **Setting range**

Overload trip [l<sub>r</sub>]
40 - 100 A

Short-circuit releases  $[I_{rm}]$ Non-delayed  $[I_i = I_n \times ...]$ 2-18

Short-circuit releases  $[I_{rm}]$ Delayed  $[I_{sd} = I_r \times ...]$ 2-10

# **TECHNICAL DATA**

### **G**eneral

Standards IEC/EN 60947

Protection against direct contact Finger and back of hand proof to VDE 0106 Part 100

Olimatic proofing Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30

Ambient temperature Ambient temperature, storage - 40 - +70 °C

Ambient temperature Operation -25 - +70 °C

Mechanical shock resistance (10 ms half-sinusoidal shock) according to IEC 60068-2-27 20 (half-sinusoidal shock 20 ms) g

Safe isolation to BN61140 Between auxiliary contacts and main contacts 500 V AC

Safe isolation to EN 61140 between the auxiliary contacts 300 V AC

Weight 3.5 kg

## Mounting position

Vertical and 90° in all directions

With XFI earth-fault release:



- NZM1, N1, NZM2, N2: vertical and 90° in all directions

with plug-in unit

- NZM1, N1, NZM2, N2: vertical,  $90^{\circ}$  right/left

with withdrawable unit:

- NZM3, N3: vertical, 90° right/left
- NZM4, N4: vertical with remote operator:
- NZM2, N(S)2, NZM3, N(S)3, NZM4, N(S)4: vertical and 90° in all directions

Direction of incoming supply as required

Degree of protection

Device

In the operating controls area: IP20 (basic degree of protection)

Degree of protection Enclosures With insulating surround: IP40 With door coupling rotary handle: IP66

Degree of protection Terminations Tunnel terminal: IP10 Phase isolator and strip terminal: IP00

Other technical data (sheet catalogue)
Weight
Temperature dependency, Derating
Effective power loss

#### Circuit-breakers

Rated current = rated uninterrupted current [ $I_n = I_u$ ] 100 A

Rated surge voltage invariability [ $U_{mp}$ ] Main contacts 8000 V

Rated surge voltage invariability  $[U_{imp}]$  Auxiliary contacts

Rated operational voltage [ $U_e$ ] 690 V AC

Overvoltage category/pollution degree III/3

Rated insulation voltage [U] 690 V

Use in unearthed supply systems  $\square$  690 V

## **Switching capacity**

Rated short-circuit making capacity [ $l_{cm}$ ] 240  $\vee$  [ $l_{cm}$ ] 187 kA

Rated short-circuit making capacity [ $l_{cm}$ ] 400/415 V [ $l_{cm}$ ] 110 kA

Rated short-circuit making capacity [l\_cm] 440 V 50/60 Hz [l\_cm] 77 kA

Rated short-circuit making capacity [l\_{cm}] 525 V 50/60 Hz [l\_{cm}] 55 kA

Rated short-circuit making capacity [ $l_{cm}$ ] 690  $\vee$  50/60 H [ $l_{c}$ ] 40 kA

Rated short-circuit breaking capacity  $l_{cn}$  [ $l_{cn}$ ] lcu to IEC/BN 60947 test cycle O-t-CO [lcu] 240 V 50/60 Hz [ $l_{cu}$ ] 85 kA

Rated short-circuit breaking capacity  $\rm l_{cn}$  [l\_{cn}] lcu to IEC/BN 60947 test cycle O-t-CO [lcu] 400/415 V 50/60 Hz [l\_{cu}] 50 kA

Rated short-circuit breaking capacity  $l_{cn}$  [ $l_{cn}$ ] lcu to IEC/BN 60947 test cycle O-t-CO [lcu] 440 V 50/60 Hz [ $l_{cu}$ ] 35 kA

Rated short-circuit breaking capacity  $I_{cn}$  [ $I_{cn}$ ] lcu to IEC/BN 60947 test cycle O-t-CO [Icu] 525 V 50/60 Hz [ $I_{cu}$ ] 25 kA

Rated short-circuit breaking capacity  $l_{cn}$  [ $l_{cn}$ ] lcu to IEC/EN 60947 test cycle O-t-CO [lcu] 690 V 50/60 Hz [ $l_{cu}$ ]

Rated short-circuit breaking capacity  $\rm l_{cn}$  [l<sub>cn</sub>] lcs to IEC/EN 60947 test cycle O-t-CO-t-CO [lcs] 240 V 50/60 Hz [l<sub>cs</sub>] 85 kA

Rated short-circuit breaking capacity  $\rm l_{cn}$  [l<sub>cn</sub>] lcs to IEC/BN 60947 test cycle O-t-OO-t-OO [lcs] 400/415 V 50/60 Hz [l<sub>cs</sub>] 50 kA

Rated short-circuit breaking capacity  $l_{cn}$  [ $l_{cn}$ ] lcs to IEC/BN 60947 test cycle O-t-OO-t-OO [lcs] 440 V 50/60 Hz [ $l_{cs}$ ] 35 kA

Rated short-circuit breaking capacity  $\rm l_{cn}$  [l<sub>cn</sub>] lcs to IEC/BN 60947 test cycle O-t-OO-t-OO [lcs] 525 V 50/60 Hz [l<sub>cs</sub>] 25 kA

Rated short-circuit breaking capacity  $\rm l_{cn}$  [l<sub>cn</sub>] lcs to IEC/EN 60947 test cycle O-t-CO-t-CO [lcs] 690 V 50/60 Hz [l<sub>cs</sub>] 5 kA

Rated short-circuit breaking capacity  $l_{cn} [l_{cn}]$  Maximum back-up fuse, if the expected short-circuit currents at the installation location exceed the switching capacity of the circuit-breaker.

Rated short-time withstand current  $t = 0.3 \text{ s } [l_{cw}]$  1.9 kA

Rated short-time withstand current  $t = 1 s [l_{ow}]$ 1.9 kA

Utilization category to IEC/EN 60947-2 A

Lifespan, mechanical(of which max. 50 % trip by shunt/undervoltage release) [Operations] 20000

Lifespan, electrical AC-1 400 V 50/60 Hz [Operations] 10000

Lifespan, electrical AC-1 415 V 50/60 Hz [Operations] 10000

Lifespan, electrical AC-1 690 V 50/60 Hz [Operations] 7500 Lifespan, electrical Max. operating frequency 120 Ops/h

Total break time at short-circuit < 10 ms

## **Terminal capacity**

Standard equipment Screw connection

Optional accessories Box terminal Tunnel terminal connection on rear

Round copper conductor Box terminal Solid 1 x (10 - 16) 2 x (6 - 16) mm²

Round copper conductor Box terminal Stranded 1 x (25 - 185) 2 x (25 - 70) mm²

Round copper conductor Tunnel terminal Solid 1 x 16 mm<sup>2</sup>

Round copper conductor Tunnel terminal Stranded 1-hole 1 x (25 - 185) mm²

Round copper conductor
Bolt terminal and rear-side connection
Direct on the switch
Solid
1 x (10 - 16)
2 x (6 - 16) mm²

Round copper conductor
Bolt terminal and rear-side connection
Direct on the switch
Stranded
1 x (25 - 185)
2 x (25 - 70) mm²

Al circular conductor Tunnel terminal Solid 1 x 16 mm<sup>2</sup>

Al circular conductor Tunnel terminal Stranded Stranded 1 x (25 - 185) mm<sup>2</sup>

Ou strip (number of segments x width x segment thickness) Box terminal [min.]  $2 \times 9 \times 0.8 \text{ mm}$ 

Ou strip (number of segments x width x segment thickness) Box terminal [max.]  $10 \times 16 \times 0.8$  (2x)  $8 \times 15.5 \times 0.8$  mm

Ou strip (number of segments x width x segment thickness) Bolt terminal and rear-side connection Hat copper strip, with holes [min.]  $2 \times 16 \times 0.8 \text{ mm}$ 

Ou strip (number of segments x width x segment thickness) Bolt terminal and rear-side connection Flat copper strip, with holes [max.]  $10 \times 24 \times 0.8 \text{ mm}$ 

Copper busbar (width x thickness) [mm] Bolt terminal and rear-side connection Screw connection MB

Copper busbar (width x thickness) [mm] Bolt terminal and rear-side connection Direct on the switch [min.] 16 x 5 mm

Copper busbar (width x thickness) [mm] Bolt terminal and rear-side connection Direct on the switch [max.] 24 x 8 mm

Control cables 1 x (0.75 - 2.5) 2 x (0.75 - 1.5) mm<sup>2</sup>

## **DESIGN VERIFICATION AS PER IEC/EN 61439**

## Technical data for design verification

Rated operational current for specified heat dissipation [I<sub>n</sub>] 100 A  $\,$ 

Equipment heat dissipation, current-dependent [R<sub>id</sub>] 8.25 W/

Operating ambient temperature min. -25  $^{\circ}$ C

Operating ambient temperature max. +70  $^{\circ}\text{C}$ 

#### IEC/EN 61439 design verification

10.2 Strength of materials and parts10.2.2 Corrosion resistanceMeets the product standard's requirements.

10.2 Strength of materials and parts 10.2.3.1 Verification of thermal stability of enclosures Weets the product standard's requirements.

10.2 Strength of materials and parts
10.2.3.2 Verification of resistance of insulating materials to
normal heat
Weets the product standard's requirements.

10.2 Strength of materials and parts
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects
Meets the product standard's requirements.

10.2 Strength of materials and parts 10.2.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements.

10.2 Strength of materials and parts
10.2.5 Lifting
Does not apply, since the entire switchgear needs to be evaluated.

10.2 Strength of materials and parts 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated.

10.2 Strength of materials and parts 10.2.7 Inscriptions Meets the product standard's requirements.

10.3 Degree of protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated.

10.4 Clearances and creepage distances Meets the product standard's requirements.

10.5 Protection against electric shock
Does not apply, since the entire switchgear needs to be
evaluated.

10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated.

10.7 Internal electrical circuits and connections Is the panel builder's responsibility.

10.8 Connections for external conductors Is the panel builder's responsibility.

10.9 Insulation properties 10.9.2 Power-frequency electric strength is the panel builder's responsibility.

10.9 Insulation properties 10.9.3 Impulse withstand voltage Is the panel builder's responsibility.

10.9 Insulation properties 10.9.4 Testing of enclosures made of insulating material is the panel builder's responsibility.

10.10 Temperature rise
The panel builder is responsible for the temperature rise
calculation. Eaton will provide heat dissipation data for the
devices.

10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed.

10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed.

10.13 Mechanical function
The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

## **TECHNICAL DATA ETIM 7.0**

Low-voltage industrial components (EG000017) / Power circuit-breaker for trafo/generator/installation protection (E0000228)

Bectric engineering, automation, process control engineering / Low-voltage switch technology / Grcuit breaker (LV < 1 kV) / Grcuit breaker for power transformer, generator and system protection (ecl@ss10.0.1-27-37-04-09 [AJZ716013])

Rated permanent current lu 100 A

Rated voltage 690 - 690 V

Rated short-circuit breaking capacity lcu at 400 V, 50 Hz  $_{50~k\Delta}$ 

Overload release current setting 40 - 100 A

Adjustment range short-term delayed short-circuit release 2 - 10  $\mbox{\sc A}$ 

Adjustment range undelayed short-circuit release 2 - 18 A

Integrated earth fault protection No
Type of electrical connection of main circuit Screw connection
Device construction Built-in device fixed built-in technique
Suitable for DIN rail (top hat rail) mounting No
DIN rail (top hat rail) mounting optional Yes
Number of auxiliary contacts as normally closed contact 0
Number of auxiliary contacts as normally open contact 0
Number of auxiliary contacts as change-over contact 0
With switched-off indicator No
With under voltage release No
Number of poles 4
Position of connection for main current circuit Front side
Type of control element Rocker lever
Complete device with protection unit Yes
Motor drive integrated No
Motor drive optional Yes
Degree of protection (IP) IP20

Characteristic curve
Let-through current
Characteristic curve
Let-through energy
DIMENSIONS
☐ Blow out area, minimum clearance to adjacent parts ☐ Minimum clearance to adjacent parts





