



192143
NZMN2-PX100-TZ

Overview

Specifications

Resources



Delivery program

Technical data

Design verification as per IEC/EN 61439

Technical data ETIM 7.0

Characteristics

Dimensions

DELIVERY PROGRAM

Product range
Circuit-breaker

Protective function
Systems, cable, selectivity and generator protection
Earth-fault protection
Zone selectivity

Standard/Approval
IEC

Installation type
Fixed

Release system
Electronic release

Construction size
NZM2

Description

LSIG overload protection and delayed and non-delayed short-circuit protective device, earth-fault protection

Class 1 energy measurement, r.m.s. value measurement, and "thermal memory"

USB interface for configuration and test function with Power Xpert Protection Manager software

Zone selectivity ZSI

Interface module in equipment supplied.

Optionally communication-capable with internal Modbus RTU module or CAM

Number of poles

3 pole

Standard equipment

Screw connection

Switching capacity

400/415 V 50 Hz [I_{cu}]

50 kA

Rated current = rated uninterrupted current [$I_n = I_u$]

Rated current = rated uninterrupted current [$I_n = I_u$]

100 A


Setting range

Overload trip

 [I_t]

40 - 100 A

Short-circuit releases  [I_{rm}]

Non-delayed  [$I = I_n \times \dots$]

2 - 18

Short-circuit releases  [I_{rm}]

Delayed  [$I_{sd} = I_n \times \dots$]

2 - 10

Setting range of earth fault release min. [$I_g = I_n \times \dots$]

20

Setting range of earth fault release max. [lg =
lnx...]
100

TECHNICAL DATA

General

Standards
IEC/EN 60947

Protection against direct contact
Finger and back of hand proof to VDE 0106 Part
100

Climatic proofing
Damp heat, constant, to IEC 60068-2-78
Damp heat, cyclic, to IEC 60068-2-30

Ambient temperature
Ambient temperature, storage
- 40 - + 70 °C


Ambient temperature
Operation
-25 - +70 °C

Mechanical shock resistance (10 ms half-
sinusoidal shock) according to IEC 60068-2-27
20 (half-sinusoidal shock 20 ms) g

Safe isolation to EN 61140
Between auxiliary contacts and main contacts
500 V AC

Safe isolation to EN 61140
between the auxiliary contacts
300 V AC

Mounting position
Vertical and 90° in all directions
With XFI earth-fault release:



- NZM1, N1, NZM2, N2: vertical and 90° in all directions

with plug-in unit

- NZM1, N1, NZM2, N2: vertical, 90° right/left

with withdraw able unit:

- NZM3, N3: vertical, 90° right/left

- NZM4, N4: vertical

with remote operator:

- NZM2, N(S)2, NZM3, N(S)3, NZM4, N(S)4: vertical and 90° in all directions

Direction of incoming supply as required

Degree of protection

Device

In the operating controls area: IP20 (basic degree of protection)

Degree of protection

Enclosures

With insulating surround: IP40

With door coupling rotary handle: IP66

Degree of protection

Terminations

Tunnel terminal: IP10

Phase isolator and strip terminal: IP00

Other technical data (sheet catalogue)

Weight

Temperature dependency, Derating

Effective power loss

Circuit-breakers

Rated current = rated uninterrupted current [$I_n = I_u$]

100 A

Rated surge voltage invariability [U_{imp}]

Main contacts

8000 V

Rated surge voltage invariability [U_{imp}]

Auxiliary contacts
6000 V

Rated operational voltage [U_e]
690 V AC

Overvoltage category/pollution degree
III/3

Rated insulation voltage [U_i]
690 V

Use in unearthed supply systems
 690 V

Switching capacity

Rated short-circuit making capacity [I_{cm}]
240 V [I_{cm}]
187 kA

Rated short-circuit making capacity [I_{cm}]
400/415 V [I_{cm}]
110 kA

Rated short-circuit making capacity [I_{cm}]
440 V 50/60 Hz [I_{cm}]
77 kA

Rated short-circuit making capacity [I_{cm}]
525 V 50/60 Hz [I_{cm}]
55 kA

Rated short-circuit making capacity [I_{cm}]
690 V 50/60 Hz [I_{cm}]
40 kA

Rated short-circuit breaking capacity I_{cn} [I_{cn}]
 I_{cu} to IEC/EN 60947 test cycle O-t-CO [I_{cu}]
240 V 50/60 Hz [I_{cu}]
85 kA

Rated short-circuit breaking capacity I_{cn} [I_{cn}]
 I_{cu} to IEC/EN 60947 test cycle O-t-CO [I_{cu}]
400/415 V 50/60 Hz [I_{cu}]
50 kA

Rated short-circuit breaking capacity I_{cn} [I_{cn}]
 I_{cu} to IEC/EN 60947 test cycle O-t-CO [I_{cu}]
440 V 50/60 Hz [I_{cu}]
35 kA

Rated short-circuit breaking capacity I_{cn} [I_{cn}]
 I_{cu} to IEC/EN 60947 test cycle O-t-CO [I_{cu}]
525 V 50/60 Hz [I_{cu}]
25 kA

Rated short-circuit breaking capacity I_{cn} [I_{cn}]
 I_{cu} to IEC/EN 60947 test cycle O-t-CO [I_{cu}]
690 V 50/60 Hz [I_{cu}]
20 kA

Rated short-circuit breaking capacity I_{cn} [I_{cn}]
 I_{cs} to IEC/EN 60947 test cycle O-t-CO-t-CO [I_{cs}]
240 V 50/60 Hz [I_{cs}]
85 kA

Rated short-circuit breaking capacity I_{cn} [I_{cn}]
 I_{cs} to IEC/EN 60947 test cycle O-t-CO-t-CO [I_{cs}]
400/415 V 50/60 Hz [I_{cs}]
50 kA

Rated short-circuit breaking capacity I_{cn} [I_{cn}]
 I_{cs} to IEC/EN 60947 test cycle O-t-CO-t-CO [I_{cs}]
440 V 50/60 Hz [I_{cs}]
35 kA

Rated short-circuit breaking capacity I_{cn} [I_{cn}]
 I_{cs} to IEC/EN 60947 test cycle O-t-CO-t-CO [I_{cs}]
525 V 50/60 Hz [I_{cs}]
25 kA

Rated short-circuit breaking capacity I_{cn} [I_{cn}]
 I_{cs} to IEC/EN 60947 test cycle O-t-CO-t-CO [I_{cs}]
690 V 50/60 Hz [I_{cs}]
5 kA

Rated short-circuit breaking capacity I_{cn} [I_{cn}]
Maximum back-up fuse, if the expected short-circuit currents at the installation location exceed the switching capacity of the circuit-breaker.

Rated short-time withstand current
 $t = 0.3$ s [I_{cw}]
1.9 kA

Rated short-time withstand current

$t = 1 \text{ s}$ [I_{cw}]

1.9 kA

Utilization category to IEC/EN 60947-2

A

Lifespan, mechanical(of which max. 50 % trip by
shunt/undervoltage release) [Operations]

20000

Lifespan, electrical

AC-1

400 V 50/60 Hz [Operations]

10000

Lifespan, electrical

AC-1

415 V 50/60 Hz [Operations]

10000

Lifespan, electrical

AC-1

690 V 50/60 Hz [Operations]

7500

Lifespan, electrical

Max. operating frequency

120 Ops/h

Total break time at short-circuit

< 10 ms

Terminal capacity

Standard equipment

Screw connection

Optional accessories

Box terminal

Tunnel terminal

connection on rear

Round copper conductor

Box terminal

Solid

1 x (10 - 16)

2 x (6 - 16) mm²

Round copper conductor
Box terminal
Stranded
1 x (25 - 185)
2 x (25 - 70) mm²

Round copper conductor
Tunnel terminal
Solid
1 x 16 mm²

Round copper conductor
Tunnel terminal
Stranded
1-hole
1 x (25 - 185) mm²

Round copper conductor
Bolt terminal and rear-side connection
Direct on the switch
Solid
1 x (10 - 16)
2 x (6 - 16) mm²

Round copper conductor
Bolt terminal and rear-side connection
Direct on the switch
Stranded
1 x (25 - 185)
2 x (25 - 70) mm²

Al circular conductor
Tunnel terminal
Solid
1 x 16 mm²

Al circular conductor
Tunnel terminal
Stranded
Stranded
1 x (25 - 185) mm²

Cu strip (number of segments x width x segment
thickness)
Box terminal [min.]
2 x 9 x 0.8 mm

Cu strip (number of segments x width x segment
thickness)
Box terminal [max.]

10 x 16 x 0.8
(2x) 8 x 15.5 x 0,8 mm

Cu strip (number of segments x width x segment thickness)
Bolt terminal and rear-side connection
Flat copper strip, with holes [min.]
2 x 16 x 0.8 mm

Cu strip (number of segments x width x segment thickness)
Bolt terminal and rear-side connection
Flat copper strip, with holes [max.]
10 x 24 x 0.8 mm

Copper busbar (width x thickness) [mm]
Bolt terminal and rear-side connection
Screw connection
M8

Copper busbar (width x thickness) [mm]
Bolt terminal and rear-side connection
Direct on the switch [min.]
16 x 5 mm

Copper busbar (width x thickness) [mm]
Bolt terminal and rear-side connection
Direct on the switch [max.]
24 x 8 mm

Control cables
1 x (0.75 - 2.5)
2 x (0.75 - 1.5) mm²

DESIGN VERIFICATION AS PER IEC/EN 61439

Technical data for design verification

Rated operational current for specified heat dissipation [I_n]
100 A

Equipment heat dissipation, current-dependent
[P_{vid}]
8.25 W

Operating ambient temperature min.
-25 °C

Operating ambient temperature max.
+70 °C

IEC/EN 61439 design verification

10.2 Strength of materials and parts
10.2.2 Corrosion resistance
Meets the product standard's requirements.

10.2 Strength of materials and parts
10.2.3.1 Verification of thermal stability of enclosures
Meets the product standard's requirements.

10.2 Strength of materials and parts
10.2.3.2 Verification of resistance of insulating materials to normal heat
Meets the product standard's requirements.

10.2 Strength of materials and parts
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects
Meets the product standard's requirements.

10.2 Strength of materials and parts
10.2.4 Resistance to ultra-violet (UV) radiation
Meets the product standard's requirements.

10.2 Strength of materials and parts
10.2.5 Lifting
Does not apply, since the entire switchgear needs to be evaluated.

10.2 Strength of materials and parts
10.2.6 Mechanical impact
Does not apply, since the entire switchgear needs to be evaluated.

10.2 Strength of materials and parts
10.2.7 Inscriptions
Meets the product standard's requirements.

10.3 Degree of protection of ASSEMBLIES
Does not apply, since the entire switchgear needs to be evaluated.

10.4 Clearances and creepage distances
Meets the product standard's requirements.

10.5 Protection against electric shock
Does not apply, since the entire switchgear needs to be evaluated.

10.6 Incorporation of switching devices and components
Does not apply, since the entire switchgear needs to be evaluated.

10.7 Internal electrical circuits and connections
Is the panel builder's responsibility.

10.8 Connections for external conductors
Is the panel builder's responsibility.

10.9 Insulation properties
10.9.2 Power-frequency electric strength
Is the panel builder's responsibility.

10.9 Insulation properties
10.9.3 Impulse withstand voltage
Is the panel builder's responsibility.

10.9 Insulation properties
10.9.4 Testing of enclosures made of insulating material
Is the panel builder's responsibility.

10.10 Temperature rise
The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.

10.11 Short-circuit rating
Is the panel builder's responsibility. The specifications for the switchgear must be observed.

10.12 Electromagnetic compatibility
Is the panel builder's responsibility. The specifications for the switchgear must be observed.

10.13 Mechanical function

The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

TECHNICAL DATA ETIM 7.0

Low-voltage industrial components (EG000017) / Power circuit-breaker for trafo/generator/installation protection (EC000228)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Circuit breaker for power transformer, generator and system protection (ecl@ss10.0.1-27-37-04-09 [AJZ716013])

Rated permanent current I_u
100 A

Rated voltage
690 - 690 V

Rated short-circuit breaking capacity I_{cu} at 400 V,
50 Hz
50 kA

Overload release current setting
40 - 100 A

Adjustment range short-term delayed short-circuit
release
2 - 10 A

Adjustment range undelayed short-circuit release
2 - 18 A

Integrated earth fault protection
Yes

Type of electrical connection of main circuit
Screw connection

Device construction
Built-in device fixed built-in technique

Suitable for DIN rail (top hat rail) mounting
No

DIN rail (top hat rail) mounting optional
Yes

Number of auxiliary contacts as normally closed
contact
0

Number of auxiliary contacts as normally open
contact
0

Number of auxiliary contacts as change-over
contact
0

With switched-off indicator
No

With under voltage release
No

Number of poles
3

Position of connection for main current circuit
Front side

Type of control element
Rocker lever

Complete device with protection unit
Yes


Mbtor drive integrated
No

Mbtor drive optional
Yes

Degree of protection (IP)
IP20

CHARACTERISTICS

Characteristic curve



Let-through current

Characteristic curve

Let-through energy

DIMENSIONS

- Blow out area, minimum clearance to adjacent parts
- Minimum clearance to adjacent parts



