



191693 NZM H2-4-VX250/VAR

Overview

Specifications

Resources







DELIVERY PROGRAM

Delivery program

Product range Orcuit-breaker

Technical data

Protective function

Systems, cable, selectivity and generator protection

Design verification as per IEC/EN 61439

Technical data ETIM 7.0

Standard/Approval

IEC

Characteristics

Installation type

Fixed

Dimensions

Release system Bectronic release

Construction size

NZM2

Description

LSI overload protection and delayed and non-

delayed short-circuit protective device Rms. value measurement and "thermal memory" USB interface for configuration and test function with Power Xpert Protection Manager software Optionally communication-capable with interface module and internal Modbus RTU module or CAM

Number of poles 4 pole

Standard equipment Screw connection

Switching capacity

 $400/415 \text{ V } 50 \text{ Hz } [l_{cu}]$ 150 kA

Rated current = rated uninterrupted current $[I_n = I_u]$

Rated current = rated uninterrupted current [$I_h = I_u$] 250 A

Neutral conductor [% of phase conductor] 0-60-100 %

Setting range

Overload trip

100 - 250 A

Short-circuit releases $[l_{rm}]$ Non-delayed $[l_i = l_n \times ...]$ 2-12

Short-circuit releases $[l_m]$ Delayed $[l_{sd} = l_r \times ...]$ $[l_{sd} = l_r \times ...]$

TECHNICAL DATA

General

Standards IEC/EN 60947

Protection against direct contact Finger and back of hand proof to VDE 0106 Part 100

Olimatic proofing Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30

Ambient temperature Ambient temperature, storage - 40 - +70 °C

Ambient temperature Operation -25 - +70 °C

Mechanical shock resistance (10 ms half-sinusoidal shock) according to IEC 60068-2-27 20 (half-sinusoidal shock 20 ms) g

Safe isolation to EN 61140 Between auxiliary contacts and main contacts 500 V AC

Safe isolation to BN 61140 between the auxiliary contacts 300 V AC

Mounting position

Vertical and 90° in all directions

90

With XFI earth-fault release:

- NZM1, N1, NZM2, N2: vertical and 90° in all directions

with plug-in unit

- NZM1, N1, NZM2, N2: vertical, 90° right/left

with withdrawable unit:

- NZMB, N3: vertical, 90° right/left

- NZM4, N4: vertical with remote operator:

- NZM2, N(S)2, NZM3, N(S)3, NZM4, N(S)4: vertical and 90° in all directions

Direction of incoming supply as required

Degree of protection Device In the operating controls area: IP20 (basic degree of protection)

Degree of protection
Enclosures
With insulating surround: IP40
With door coupling rotary handle: IP66

Degree of protection
Terminations
Tunnel terminal: IP10
Phase isolator and strip terminal: IP00

Other technical data (sheet catalogue)
Weight
Temperature dependency, Derating
Effective power loss

Circuit-breakers

Rated current = rated uninterrupted current [$I_n = I_{ul}$] 250 A

Rated surge voltage invariability [U_{mp}] Main contacts $8000\ V$

Rated surge voltage invariability [U_{mp}] Auxiliary contacts $6000\ V$

Rated operational voltage $[U_e]$ 690 V AC

Overvoltage category/pollution degree III/3

Rated insulation voltage [U_i] 690 V

Use in unearthed supply systems $\hfill\Box$ 690 V

Switching capacity

Rated short-circuit making capacity [l_{cm}] 240 V [l_{cm}] 330 kA

Rated short-circuit making capacity [l_{cm}] 400/415 V [l_{cm}] 330 kA

Rated short-circuit making capacity [l_{cm}] 440 V 50/60 Hz [l_{cm}] 286 kA

Rated short-circuit making capacity [l_{cm}] 525 V 50/60 Hz [l_{cm}] 110 kA

Rated short-circuit making capacity [l_{cm}] 690 V 50/60 H [lc] 40 kA

Rated short-circuit breaking capacity l_{cn} [l_{cn}] lcu to IEC/EN 60947 test cycle O-t-CO [lcu] 240 V 50/60 Hz [l_{cu}] 150 kA

Rated short-circuit breaking capacity l_{cn} [l_{cn}] lcu to IEC/EN 60947 test cycle O-t-CO [lcu] 400/415 V 50/60 Hz [l_{cu}] 150 kA

Rated short-circuit breaking capacity l_{cn} [l_{cn}] lcu to IEC/EN 60947 test cycle O-t-CO [lcu] 440 V 50/60 Hz [l_{cu}] 130 kA

Rated short-circuit breaking capacity l_{cn} [l_{cn}] lcu to IEC/EN 60947 test cycle O-t-CO [lcu] 525 V 50/60 Hz [l_{cu}] 50 kA

Rated short-circuit breaking capacity l_{cn} [l_{cn}] lcu to IEC/EN 60947 test cycle O-t-CO [lcu] 690 V 50/60 Hz [l_{cu}] 20 kA

Rated short-circuit breaking capacity l_{cn} [l_{cn}] lcs to IEC/EN 60947 test cycle O-t-CO-t-CO [lcs] 240 V 50/60 Hz [l_{cs}] 150 kA

Rated short-circuit breaking capacity l_{cn} [l_{cn}] lcs to IEC/EN 60947 test cycle O-t-OO-t-OO [lcs] 400/415 V 50/60 Hz [l_{cs}] 150 kA

Rated short-circuit breaking capacity l_{cn} [l_{cn}] lcs to IEC/EN 60947 test cycle O-t-CO-t-CO [lcs] 440 V 50/60 Hz [l_{cs}] 130 kA

Rated short-circuit breaking capacity l_{cn} [l_{cn}] lcs to IEC/EN 60947 test cycle O-t-CO-t-CO [lcs] 525 V 50/60 Hz [l_{cs}] 37.5 kA

Rated short-circuit breaking capacity l_{cn} [l_{cn}] lcs to IEC/EN 60947 test cycle O-t-OO-t-OO [lcs] 690 V 50/60 Hz [l_{cs}] 5 kA

Rated short-circuit breaking capacity l_{cn} [l_{cn}] Maximum back-up fuse, if the expected short-circuit currents at the installation location exceed the switching capacity of the circuit-breaker.

Rated short-time withstand current $t = 0.3 \, s \, [l_{cw}]$ 1.9 kA

Rated short-time withstand current $t = 1 \text{ s } [I_{cw}]$ 1.9 kA

Utilization category to IEC/EN 60947-2 A

Lifespan, mechanical(of which max. 50 % trip by shunt/undervoltage release) [Operations]

Lifespan, electrical AC-1 400 V 50/60 Hz [Operations] 10000

Lifespan, electrical AC-1 415 V 50/60 Hz [Operations] 10000

Lifespan, electrical AC-1 690 V 50/60 Hz [Operations] 7500

Lifespan, electrical Max. operating frequency 120 Ops/h

Total break time at short-circuit < 10 ms

Terminal capacity

Standard equipment Screw connection

Optional accessories Box terminal Tunnel terminal connection on rear

Round copper conductor Box terminal Solid 1 x (10 - 16) 2 x (6 - 16) mm²

Round copper conductor Box terminal Stranded 1 x (25 - 185) 2 x (25 - 70) mm²

Round copper conductor Tunnel terminal Solid Round copper conductor Tunnel terminal Stranded 1-hole 1 x (25 - 185) mm²

Round copper conductor
Bolt terminal and rear-side connection
Direct on the switch
Solid
1 x (10 - 16)
2 x (6 - 16) mm²

Round copper conductor
Bolt terminal and rear-side connection
Direct on the switch
Stranded
1 x (25 - 185)
2 x (25 - 70) mm²

Al circular conductor Tunnel terminal Solid 1 x 16 mm²

Al circular conductor Tunnel terminal Stranded Stranded 1 x (25 - 185) mm²

Ou strip (number of segments x width x segment thickness)

Box terminal [min.]

2 x 9 x 0.8 mm

Quistrip (number of segments x width x segment thickness)
Box terminal [max.]
10 x 16 x 0.8
(2x) 8 x 15.5 x 0,8 mm

Ou strip (number of segments x width x segment thickness)

Bolt terminal and rear-side connection

Flat copper strip, with holes [min.]

2 x 16 x 0.8 mm

Ou strip (number of segments x width x segment

thickness)
Bolt terminal and rear-side connection
Flat copper strip, with holes [max.]
10 x 24 x 0.8 mm

Copper busbar (width x thickness) [mm] Bolt terminal and rear-side connection Screw connection M8

Copper busbar (width x thickness) [mm] Bolt terminal and rear-side connection Direct on the switch [min.] 16 x 5 mm

Copper busbar (width x thickness) [mm] Bolt terminal and rear-side connection Direct on the switch [max.] 24 x 8 mm

Control cables 1 x (0.75 - 2.5) 2 x (0.75 - 1.5) mm²

DESIGN VERIFICATION AS PER IEC/EN 61439

Technical data for design verification

Rated operational current for specified heat dissipation $[I_n]$ 250 A

Equipment heat dissipation, current-dependent $[P_{id}]$ 51.5625 W

Operating ambient temperature min. -25 °C

Operating ambient temperature max. +70 $^{\circ}\text{C}$

IEC/EN 61439 design verification

10.2 Strength of materials and parts10.2.2 Corrosion resistanceWeets the product standard's requirements.

10.2 Strength of materials and parts 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements.

10.2 Strength of materials and parts10.2.3.2 Verification of resistance of insulating materials to normal heatMeets the product standard's requirements.

10.2 Strength of materials and parts 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects Weets the product standard's requirements.

10.2 Strength of materials and parts 10.2.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements.

10.2 Strength of materials and parts10.2.5 LiftingDoes not apply, since the entire switchgear needs to be evaluated.

10.2 Strength of materials and parts10.2.6 Mechanical impactDoes not apply, since the entire switchgear needs to be evaluated.

10.2 Strength of materials and parts10.2.7 InscriptionsMeets the product standard's requirements.

10.3 Degree of protection of ASSEVBLIES Does not apply, since the entire switchgear needs to be evaluated.

10.4 Clearances and creepage distances Meets the product standard's requirements.

10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components

Does not apply, since the entire switchgear needs to be evaluated.

10.7 Internal electrical circuits and connections Is the panel builder's responsibility.

10.8 Connections for external conductors Is the panel builder's responsibility.

10.9 Insulation properties 10.9.2 Power-frequency electric strength Is the panel builder's responsibility.

10.9 Insulation properties 10.9.3 Impulse withstand voltage Is the panel builder's responsibility.

10.9 Insulation properties10.9.4 Testing of enclosures made of insulating materialIs the panel builder's responsibility.

10.10 Temperature rise
The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.

10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed.

10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed.

10.13 Mechanical function
The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

TECHNICAL DATA ETIM 7.0

Low-voltage industrial components (EG000017) / Pow er circuit-breaker for trafo/generator/installation protection (EC000228)

Bectric engineering, automation, process control engineering / Low-voltage switch technology / Orcuit breaker (LV < 1 kV) / Orcuit breaker for power transformer, generator and system protection (ecl@ss10.0.1-27-37-04-09 [AJZ716013])

Rated permanent current lu 250 A

Rated voltage 690 - 690 V

Rated short-circuit breaking capacity Icu at 400 V, 50 Hz 150 kA

Overload release current setting 100 - 250 A

Adjustment range short-term delayed short-circuit release 2 - 10 A

Adjustment range undelayed short-circuit release 2 - 12 A

Integrated earth fault protection No

Type of electrical connection of main circuit Screw connection

Device construction

Built-in device fixed built-in technique

Suitable for DIN rail (top hat rail) mounting No

DIN rail (top hat rail) mounting optional Yes

Number of auxiliary contacts as normally closed contact

Number of auxiliary contacts as normally open contact 0	
Number of auxiliary contacts as change-over contact 0	
With switched-off indicator No	
With under voltage release No	
Number of poles 4	
Position of connection for main current circuit Front side	
Type of control element Rocker lever	
Complete device with protection unit Yes	
Motor drive integrated No	
Motor drive optional Yes	
Degree of protection (IP) IP20	

CHARACTERISTICS

Characteristic curve



Let-through current

Characteristic curve



Let-through energy

DIMENSIONS



 $\hfill \square$ Blow out area, minimum clearance to adjacent ports

 $\hfill \square$ Minimum clearance to adjacent parts









Imprint | Privacy Policy | Legal Disclaimer | Terms and Conditions © 2022 by Eaton Industries GmbH